



**(A)** SEE STD. SPEC. SECTION 13.20 FOR SLIP BY HUB ADAPTER FOR PVC SEWER MAINS.

- NOTES:**
1. THE FULL LENGTH OF THE SERVICE DITCH SHALL BE COMPACTED IN 6" LAYERS WITH MECHANICAL TAMP. GUARD STAKE REQUIRED AT CLEANOUT LOCATION UNTIL LANDSCAPING IS COMPLETED.
  2. DIP LATERAL CONNECTIONS REQUIRED WHERE MAINLINE IS GREATER THE 14' DEEP. TEES INSTEAD OF SADDLES TO BE USED.

REVISED	DATE: 6/7/84	<b>Standard Detail</b>	OFFICE OF THE
JWL 5/86 DD 9/1/87 CG 2/17/86 EZ 3/29/89 DS 7/15/96 DS 10/15/97 8/31/99 1/6/05	SCALE: NONE		<b>CITY ENGINEER</b>
MB 8/31/21 AB 12/2/22 MB 01/09/26	DRAWN BY: KAB, MGB	<b>Sanitary Sewer Lateral Connection</b>	
	CHECKED BY: DCC, FAP, TAJ		
	CITY ENGINEER: DEC, JPB, GVS		