



GENERAL NOTES:

1. MANHOLE RING AND COVERS CANNOT BE COVERED, OR OBSCURED BY LANDSCAPING, PAVEMENT, ETC.
2. INLET AND OUTLET PIPES SHOULD BE SCHEDULE 40 PVC, AND CANNOT BE COVERED OR CAPPED.
3. INLET PIPE MUST BE A MINIMUM OF 4" IN DIAMETER. VERTICAL PIPE ON OUTLET SIDE MUST BE A MINIMUM OF 6" IN DIAMETER.
4. TRAPS SHOULD NOT BE LOCATED IN AN ENTRANCE, EXIT, DRIVE-THRU, OR UNDER A MENU BOARD. IF TRAP IS LOCATED IN A DRIVE/PARKING AREA, IT MUST CONTAIN TRAFFIC RATED RINGS AND COVERS AND MEET H-20 LOADING.
5. MINIMUM SIZE : 1000 GALLONS
6. 2" DIAMETER VENTS TO BE CONNECTED TO BUILDING VENT SYSTEM.

1" BUTYL RUBBER MASTIC SEALANT

REVISED	F.B.	PG.	DATE: 5/21/02
			SCALE: NTS
			DRAWN BY: MHW
			CHECKED BY: DFD
			CITY ENGINEER: FAP

STANDARD DETAIL  
IN GROUND GREASE INTERCEPTOR

OFFICE OF THE  
CITY ENGINEER  
GASTONIA, N.C.

FILE NO. 71B-28B