



**DROP MANHOLE**  
 USE WHERE DIFFERENCE OF  
 INVERT ELEVATION IS GREATER  
 THAN 2'-6" (30")

**NOTES:**

1. ALL PIPING & MATERIALS TO BE MECHANICALLY RESTRAINED DIP (MEGA-LUG OR APPROVED EQUAL).
2. ALL CONNECTIONS TO PRECAST MANHOLE STRUCTURE TO BE WATERTIGHT.

REVISED	DATE: 02-02-2015
02-13-26	SCALE: NONE
	DRAWN BY: BJP, MGB
	CHECKED BY: GVS, BJP, JKL
	CITY ENGINEER: CCB, JKL

**Standard Detail**  
  
**Outside Drop Detail**

OFFICE OF THE <b>CITY ENGINEER</b>  GASTONIA, N.C.
FILE NO. <b>71B-3</b>