



**NOTES:**

1. USE DUCTILE IRON PIPE FOR HYDRANT INSTALLATION.
2. CONCRETE TO BE PLACED AT TEE AS SHOWN, KEEP BOLTS FREE OF CONCRETE.
3. FRICTION TYPE RESTRAINT WILL NOT BE ALLOWED FOR USE ON DEAD ENDS.
4. IF BLOW-OFF ASSEMBLY IS USED, REPLACE MJ PLUG WITH MJ REDUCER, (SEE COG DETAIL 71B-9B)

**SECTION A-A**

REVISED	DATE: 03-20-1974	<b>Standard Detail</b>	OFFICE OF THE <b>CITY ENGINEER</b>
	04/23/15		GASTONIA, N.C.
	SCALE: NONE	<b>Fire Hydrant Leg &amp; Dead End Detail</b>	FILE NO. <b>71B-9</b>
	DRAWN BY: RMN, EZ		
	CHECKED BY: NBM, FAP		
	CITY ENGINEER: JPB		