



TOP ELEV.

TYPICAL SECTION A-A

NOTE: SEE FILE NO. 71C-18 & 19  
FOR DIMENSIONS  
SEE 71C-10 FOR FRONT ELEV.

NOTE: 1 (ONE) CUBIC FOOT MINIMUM OF #57 WASHED  
STONE IS REQUIRED BEHIND EACH WEEP HOLE.

NOTE: FILL EVERY CAVITY COMPLETELY  
WITH 3000 PSI CONCRETE.

CONCRETE SHALL NOT FALL  
MORE THAN THE HEIGHT OF 5  
LAYERS OF BLOCK.

REVISED	F.B.	PG.	DATE: <b>4/22/74</b>
<b>5/21/79</b>			SCALE: <b>None</b>
<b>9/14/90</b>			DRAWN BY: <b>PNR</b>
			CHECKED BY: <b>NBM, FAP</b>
			CITY ENGINEER: <b>DEC</b>

**Standard Detail**  
**Concrete Block Headwall  
With Wing Walls**

OFFICE OF THE  
CITY ENGINEER  
GASTONIA, N.C.  
FILE NO. **71C-11**