



TOP ELEV.

TYPICAL SECTION A-A

NOTE: SEE FILE NO. 71C-18 & 19 FOR DIMENSIONS AND 71C-16 FOR FRONT ELEV.

NOTE: 1 (ONE) CUBIC FOOT MINIMUM OF #57 WASHED STONE IS REQUIRED BEHIND EACH WEEP HOLE.

NOTE: FILL CAVITY COMPLETELY WITH 3000 PSI CONCRETE.

CONCRETE SHALL NOT FALL MORE THAN THE HEIGHT OF 5 LAYERS OF BRICK.

REVISED	F.B.	PG.	DATE: 4/20/74
3/21/73			SCALE: None
9/14/90			DRAWN BY: PNR
			CHECKED BY: NBM, FAP
			CITY ENGINEER: DEC

Standard Detail
Reinforced Brick Headwall With Wing Walls
For 54" RCP and Over
(With Reinforced Steel)

OFFICE OF THE
CITY ENGINEER
 GASTONIA, N.C.

FILE NO. **71C-17**