

NOTES:

- 1.) RIP-RAP STONE FILTERS SHALL BE PLACED AT 200 FT. INTERVALS
- 2.) TRAP CAPACITY SHALL BE INITIALLY 67 CY. EACH IN VOLUME. (MAXIMUM DRAINAGE AREA IS 5.0 AC.)
- 3.) TRAP AREA IS TO BE MAINTAINED IN OPERATING ORDER AT ALL TIMES. DURING AND AFTER EACH RAIN THE FILTERS AND TRAPS AREAS ARE TO BE CHECKED AND CLEANED WHEN VOLUME IS REDUCED BY ONE-HALF. SPOILS ARE TO BE BURIED IN AN APPROVED AREA INSIDE THE CONSTRUCTION R/W OR DISPOSED OF OFFSITE BY THE CONTRACTOR.
- 4.) RIP-RAP SHALL BE USED FOR TEMPORARY STREAM CROSSINGS WHERE THE CONTRACTOR HAS TO CONTINUE ITS USE FOR INGRESS AND EGRESS TO THE PROJECT AREAS. A TEMPORARY CROSSING PIPE MAY BE USED WHERE NECESSARY AS SHOWN ON VIRGINIA DEPARTMENT OF HIGHWAYS STANDARD NO. 1.47.

SEE STANDARD DETAIL 71C-32 FOR DRAWINGS

REVISED	F.B.	PG.	DATE: 10-3-88	<b>STANDARD DETAIL</b>	OFFICE OF THE CITY ENGINEER GASTONIA, N.C.
			SCALE: NOT TO SCALE		
			DRAWN BY: JDH		<b>PERIMETER SILT DITCH WITH SEDIMENT TRAP FOR SANITARY SEWER OUTFALL CONSTRUCTION</b>
			CHECKED BY: PNR,FAP		
			CITY ENGINEER: DEC	FILE NO. <b>71C-33</b>	