

Table 2 Runoff Coefficients for Storm Sewers

Description of Area	Runoff Coefficients
Business:	
Downtown areas	0.95
Neighborhood areas	0.70
Residential:	
Single-family areas	0.40
Multi units, detached	0.60
Multi units, attached	0.70
Residential (suburban)	0.35
Apartment dwelling areas	0.70
Industrial:	
Light areas	0.70
Heavy areas	0.80
Parks, cemeteries	0.20
Playgrounds	0.30
Railroad yards	0.30
Unimproved areas	0.25

Tables 1, 2 & 3 are applicable for storms of 5- to 10-year frequencies. Less frequent higher intensity storms require higher coefficients. Coefficients are based on assumption that the design storm does not occur when ground surface is frozen.

Note: Table adapted from "Design and Construction of Sanitary and Storm Sewer",
A Joint Committee of the American Society of Civil Engineers and the Water Pollution
Control Federation, 1969, P. 51

REVISED	F.B.	PG.	DATE: AUGUST 30, 1974	STANDARD DETAIL RUNOFF COEFFICIENTS FOR USE IN THE RATIONAL METHOD FOR CALCULATING STORM DRAINAGE RUNOFF	OFFICE OF THE CITY ENGINEER GASTONIA, N.C.
5/21/75			SCALE: NONE		
			DRAWN BY:		
			CHECKED BY:		
			CITY ENGINEER:		
					FILE NO. 71G-5B