



NOTE: THERE WILL BE ONE HYDRANT AT EACH INTERSECTION WITH INTERMEDIATE HYDRANTS SO THAT THEY ARE NOT OVER 500 FEET APART FOR RESIDENTIAL AREAS (250' FOR OTHER DISTRICTS). ALL BUILDINGS WITH FIRE DEPARTMENT CONNECTIONS (FDC) SHALL HAVE ONE HYDRANT DESIGNATED FOR FDC USE WITHIN 100' OF CONNECTION, THEN ANOTHER HYDRANT SPACED 250'; THEN BEGIN PROPER SPACING. VALVE LOCATIONS SHOWN ARE APPROXIMATE, SEE PROJECT INSPECTOR FOR FINAL FIELD LOCATION - FOR DIMENSIONS REQUIRED ON AS-BUILTS, SEE STD. SPEC. SECTION 2.63.

REVISED	F.B.	PG.	DATE: 3-20-74
12/6/84			SCALE: NONE
1/23/89			DRAWN BY: BMP
12/01/00			CHECKED BY: DFD
			CITY ENGINEER: JPB

STANDARD DETAIL

VALVE & FIRE HYDRANT
LOCATION DETAIL

OFFICE OF THE
CITY ENGINEER
GASTONIA, N.C.

FILE NO. **71B-6**